


# SharkFins

Pearl, Svenja, Mateo



Site | Initial Massing | Benchmarking

# Site

Location: Seattle, Washington

ASHRAE Climate Zone 4C

Architects: Mateo

Engineer: Svenja

Project Manager: Pearl

## Guiding Principles

- Minimize unoccupied hours
- Maximize occupant comfort
- Achieve low EUI by responding to the climate





# Location



# Surroundings-Urban Setting



# Climate Context




Climate Zone: 4C

# Initial Massing




# EUI Benchmarking



- Roof Area: 1630 m<sup>2</sup>
- Footprint: 5800 m<sup>2</sup>
- 1267kWh/m<sup>2</sup>-y total solar radiation on PV surface
- Assumed PV efficiency: 18%
- Assumed inverter efficiency: 96%
- Max EUI that PV system can support: 61.5 kWh/m<sup>2</sup> (19.5 BTU/ft<sup>2</sup>)

**Target EUI: below 61 kWh/m<sup>2</sup> (19.5 BTU/ft<sup>2</sup>)**

# EUI Benchmarking



**Office buildings** in climate zone **4C** (built between 2000-2021)









Building has to be in the **98<sup>th</sup> percentile** to be net zero

**Target EUI: below 61 kWh/m<sup>2</sup> (19.5 BTU/ft<sup>2</sup>)**



Daylight | Electric Light



# Daylight Concept Overview




**sDA = 100%**  
**ASE = 39.2%**

**sDA = 86.8%**  
**ASE = 17.3%**

**sDA = 59.8%**  
**ASE = 13%**











# Atrium Study



**Centro de Investigación, H Arquitects.** <https://www.archdaily.cl/cl/767655/centro-de-investigacion-icta-icp-star-uab-h-arquitectes-plus-dataae/5567b61de58eabd7a0000ae-centro-de-investigacion-icta-icp-star-uab-h-arquitectes-plus-dataae-foto>

# Atrium Daylight Autonomy Study






**sDA = 59.8%**  
**ASE = 13%**




**sDA = 75.7%**  
**ASE = 12.4%**

**sDA = 87.1%**  
**ASE = 14.7%**

# Annual Solar Exposure



89.8%  
sDA<sub>300/50%</sub>




22.0%  
ASE<sub>1000,250</sub>

1<sup>st</sup> Floor


2<sup>nd</sup> Floor

3<sup>rd</sup> Floor

# Façade Shading Study




- Vertical shading panels on the East and West facades
- Targeting glare probability resulting from low sun in the mornings/afternoon



- Horizontal shading light shelves on the south facade
- Targeting glare probability resulting from high sun angles

# Low-tech rolling shading device






# Façade Shading Study

No Shading


EW Shading Panels

S Light Shelves


89.8%  
sDA<sub>300/50%</sub>




82.3%  
sDA<sub>300/50%</sub>




87.0%  
sDA<sub>300/50%</sub>




22.0%  
ASE<sub>1000,250</sub>






10.9%  
ASE<sub>1000,250</sub>




17.4%  
ASE<sub>1000,250</sub>




# Glare Study



17.9%  
sDG (% views with Disturbing Glare >5% of time)




9.9%  
sDG (% views with Disturbing Glare >5% of time)




13.3%  
sDG (% views with Disturbing Glare >5% of time)

# South Facade Workspace


South facing open-office space  
without any shading or light shelves



South facing open-office space with  
added light shelves





South facing open-office space with  
added **light shelves** and **operable shades**



Nov. 13 at 11:00AM


# LUMINAIRE PLACEMENT - CIRCULATION V WORKING



- Enough lighting was spaced in the working and circulation area to achieve 300 lux and 150 lux respectively
- These analyses were performed at 10pm when there is no daylight

# LUMINAIRE PLACEMENT - INDIRECT V DOWNLIGHT

Direct/Indirect Lights in the working space



Dowlights in the working space

Final Design: Direct/Indirect Lights in the working space



- On the left we see the effects of the two different types of lighting on the lighting at the desk/working level
- The downlights create more intense downshadows while the direct/indirect lights create more evenly distributed results

# Lighting Power Density LPW Calculation




LPW Workspace		
Total area	122	m <sup>2</sup>
Number of Luminaires	16	-
Wattage of each Luminaire	29	W
LPW Workspace	3.80	W/m <sup>2</sup>
LPW Circulation		
Total area	60	m <sup>2</sup>
Number of Luminaires	4	-
Wattage of each Luminaire	24	W
LPW Circulation	1.6	W/m <sup>2</sup>

$$(29 \times 16 / 122)$$


$$(24 \times 4 + 29 \times 16) / (60 + 122)$$

<b>LPW Overall</b>	<b>3.077</b>	<b>W/m<sup>2</sup></b>
--------------------	--------------	------------------------

$$(24 \times 4 / 60)$$




# Typical Floorplan






Environmental Concept | EUI

# Occupancy and Schedule



Happy Hour



■ Cooling 
 ■ Heating 
 ■ Hot Water 
 ■ Lighting 
 ■ Equipment Fan 
 ■ Equipment

# Occupancy and Schedule – Ping Pong Concept



Happy Hour




The Ping Pong/ Meeting Rooms can be used for ping pong or meetings/hot-desking by the employees. If they are free, they can be rented by visitors.

- Workers
- Workers play-ign ping pong
- Visitors

# EUI vs Energy Milage

## EUI



## Energy Milage


**0.95** pers\*h/kWh

**1.15** pers\*h/kWh




# Thermal Zoning


Shading geo




Internal atrium zone





North/South core zones




North/South perimeter zones



windows




# Lighting Adjustments



**- 20 %**

- Dimming
- LED Fixtures


# Added Insulation



**- 11%**

- Roof | 0.364 to 0.17 W/m<sup>2</sup>K
- Façade | 0.67 to 0.165 W/m<sup>2</sup>K

# Shading System



- South balconies as overhang
- Manual exterior shading east and west

**- 1%**




# Tighten Envelope



- Infiltration | 0.1 to 0.05 ach

**- 3%**


# Heat Recovery




- Heat Recovery Efficiency | 0.8

**- 10 %**


# HVAC System Comparison




# HVAC System Comparison




# HVAC | EUI




# HVAC | Cost over 50 years



# HVAC | Cost over 50 years



# HVAC | Cost over 50 years




VRF|DOAS uses **20 times** less space than VAV|ECO

**VRF|DOAS** is implemented into the design







# Final EUI




Target EUI: below **61**  
**kWh/m<sup>2</sup>** (19.5 BTU/ft<sup>2</sup>)




# Shading Study – PV Placement



# PV Placement – Self Shading



No PV in shaded area  
(lower 3 m of roof)



# PV Yield - Comparison



Initial massing


307,500 kWh annually

~ + 50 %

Final Design

459,035 kWh annually

# Environmental Features



**VRF System**  
**DOAS and heat recovery**

**Overhang**  
-glare and solar gain control  
-balcony

**PV** ⚡  
condensing unit  
AHU

VRF cassettes

**PV** ⚡

**Skylights**  
-daylight

**PV** ⚡

**LED**  
+ Dimming

**Movable elements**  
-glare and solar gain control

Baywater System Supply

Concluding Thoughts

# Conclusions

## Minimize unoccupied hours

- Amenity space open to the public

## Maximize occupancy comfort

- Individualized control of shading and glare protection elements
- Recreational spaces
- Skylight and atrium daylight concept
- Atrium, meeting spaces and balconies encourage collaboration

## Achieve low EUI by responding to the climate

- Roof Concept - Skylights + PV
- Baywater as water loop for condensing unit of VRF

